



Power Guard 6KVA 6000VA 6000W Online UPS

Sale Price: 146500.0

PRODUCT ID: 0015219

Main Feature	
Capacity	6000VA
Load Capacity	6000W / 5400W / 4800W
Input Voltage	Nominal Voltage: 200/208/220/230/240VAC Frequency Range: 46Hz-54Hz / 56Hz-64Hz Phase: Single phase with ground Power Factor: R0.99 @ nominal voltage (100% load)
Output Voltage	AC Voltage Regulation (Batt. Mode): 2% Current Crest Ratio: 3:01 Frequency Range (Batt. Mode): 50 Hz 0.2 Hz or 60 Hz 0.2 Hz Frequency Range (Synchronized Range): 46 ~ 54 Hz or 56 ~ 64 Hz Harmonic Distortion: Q4 % THD (Linear Load) Q 6 % THD(For Full RCD Load,PF=0.8) Output Voltage: 110/115/120/127 VAC or 208/220/230/240 VAC Transfer Time: Line mode to Battery mode Zero Waveform (Batt. Mode): Pure Sine Wave
Battery	Battery Type: 12 V / 8.2 AH Numbers: 16 Typical Recharge Time: 6 hours recovery to 90% capacity Charging Current (max.): 1.0A/2.0A/4.0 A/6.0A DC Voltage: 192 VDC
Alarm	Battery Mode: Sounding every 4 seconds Low Battery: Sounding every second Overload: Sounding twice every second Fault: Continuously sounding
Indications	LED Panel: UPS status, Load level, Battery level, Input/Output voltage, and Fault conditions
Others	Optional SNMP: Power management from SNMP manager and web browser
Physical Specification	
Dimension	260*642 *582mm
Manufacture Warranty	



MUNSHIGANJ IT

We Connect Whole Narayanganj...

Genuine Product | Genuine Price | Genuine Service | Genuine Care

194, Banghabandhu Road, Shomobay New Market (2nd Floor)

Shop No- 117,118,103 & 104, Level-2, Somobay New Market,

Chasara, Narayanganj-1400, Bangladesh

www.munshiganjit.com.bd e-mail-info@munshiganjit.com.bd

Hotline-09614-502244

Sales-01979490143, Corporate- 01979999722

MITCare- 01979490145, Warranty-01979490146

CCTV-01979490147, Web team- 01979999711

OUR SHOP

TECH BD21
We Connect Whole Narayanganj...

Shop No- 16, 3rd Floor, Central
Plaza, Signboard, Narayanganj



193, President Road, Siraj
Mansion (4th Floor),
Chasara, Narayanganj



**MIT
Care**

193, President Road, Siraj
Mansion (4th Floor),
Chasara, Narayanganj



50%
Delivery Charge
Inside Narayanganj City

**HOME
DELIVERY**

অনলাইনে অর্ডার করতে ভিজিট করুন
www.munshiganjit.com.bd



- UPS burning due to thunder, abnormal overload, insect entrance and others.
- If ambient temperature should not be maintained at 20 to 26 degrees Celsius with proper dehumidification. (24/7)
- If the product is placed in a dusty and damp place.
- In the absence of Generator connectivity Without proper battery charge, the warranty will be void.
- Battery swelling and overcharging due to the wrong system voltage setting of the UPS.